



DEPUTY DIRECTOR, HEALTH SERVICES
STATE PUBLIC HEALTH LABORATORY, PUNE.
Near St. Mary School And Church, Pune 411001

Telephone - Office :- (020) 263300225 Ext. 223

Email : statehealthlab@gmail.com



HEALTH SERVICES

NO. SPHL PUNE /Desk -79 / 547 / 2025. DATE :- 13 /05 /2025.

Report on Chemical Analysis of Drinking Water

Sent by :- Holy Spirit Convent School, Lonikand , Haveli Pune.

With Ref. letter No :- -----

Dated :- 16/04/2025

Date of Collection :- -----

Date of Receipt :- 16-04-2025

Date of Examination :- 18 / 04 / 2025 onwards

(All the Analytical Results are in mg. / Lit. except pH , Turbidity)


SR. NO	TEST PARAMETER	S.No. - 1 (P-397) Borewell Water	BIS Specifications 10500 : 2012 Normal Values	
			Desirable limit	Permissible limit
1	Physical Appearance	Clear	---	---
2	Odour	agreeable	agreeable	agreeable
3	Turbidity (as N.T.U.)	0.55	1.0	5.0
4	pH Value	7.02	6.5 to 8.5	No relaxation
5	Chlorides (as Cl)	10.92	250	1000
6	Nitrates (as No3)	16.00	45	No relaxation
7	Total Hardness (as Caco3)	9.49	200	600
8	Alkalinity (as Caco3)	14.18	200	600
9	Total Dissolved Solids	48.0	500	2000
10	Iron (as Fe)	0.037	1.0	No relaxation
11	Fluoride (as F)	0.52	1.0	1.5

- This report is restricted only for the sample /s submitted to this laboratory.
- It is presumed that the representative sample from the source is sent for analysis.
- This Sample /s is /are not collected by this laboratory.

Remark :- S.No. 1 -is chemically fit for drinking purpose on the basis of analysed parameters. Only. However, this water source can be used for drinking purpose only after proper treatment, disinfection & ascertaining its bacteriological quality frequently or regularly.

Forwarded With Compliments to :- Holy Spirit Convent School, Lonikand , Haveli Pune.

Fees	600 /-
Receipt No.	5119766
Date	16/04/2025


Senior Scientific Officer
State Public Health Laboratory
Pune-411 001

PROFORMA REGARDING SAFE DRINKING WATER AND
SANITARY CONDITION CERTIFICATE

No.

Date:10-06-2025

It is certified that an inspection team headed by Dr. Shaila Fad, Medical Officer, from Primary Health Centre, Perane Tel- Haveli, Dist. Pune inspected the Holy Spirit Convent school, Lonikand Pune on 17th June 2023 And found that the Holy Spirit Convent School, Lonikand has safe drinking water facilities for the students and members of staff of the institution and maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the central/State/U.T Govt.

The Above valid for a period of 10/06/2025 To 09/06/2026

Signature with Seal:

Name: Dr. Nilima Inamdar

Designation: Medical Officer

Primary Health Center

Perane, Pune.

वैद्यकीय अधिकारी
प्राथमिक आरोग्य केंद्र पेरणे
ता हवेली जि पुणे



To,

PRINCIPAL,

HOLY SPIRIT CONVENT SCHOOL,

LONIKAND, HAVELI, PUNE-412216.